



MANHOLE REHABILITATION PROJECT

Invitation to Bid Amendment #1

The following changes / clarifications / additions have been added to the Invitation to Bid project specifications and plans:

1. **QUESTION:** What are the distances between the street and the manholes for the seven that are located on private property/backyards?

ANSWER: Estimated lengths from the edge of pavement are as follows:

1E11 - 90 feet
1F3 - 150 feet
4B7 - 40 feet (access through private parking lot)
4D19 - 150 feet
4D20 - 150 feet
6A27 - 150 feet
SR4605 - 150 feet

Note: 1E11 was listed incorrectly in the table in line 8 as 1B33.

2. **QUESTION:** ...Please find the information for the product/ products (Raven 405 Epoxy/ Strong Seal MS2A)... (Is) the attached information enough to have Raven 405 Epoxy approved as an equal?

ANSWER: The **Strong Seal MS2A** for substrate repair, and the **Raven 405 Epoxy** as the corrosion barrier, is approved for this work.

Attachments: none

Contacts for this proposal:

Joan M. Schouten CPIM CPPB; Procurement Officer; JSchouten@wheaton.il.us