



## MANHOLE REHABILITATION PROJECT

### Invitation to Bid Amendment #2

*The following changes / clarifications / additions have been added to the Invitation to Bid project specifications and plans:*

1. **QUESTION:** ...Please find the information for the Madewell Composite Liner which includes the following products :

ML-72 Restoration Mortar

DS-5 100% solids epoxy coating

806 flexible chimney seal which we install on all of our manhole rehabilitation (included in the cost)

ML-10 hydraulic cement used to patch and seal prior to ML-72

**ANSWER:** The above products are not approved. This product appears to be a cementitious coating system as opposed to the required polymer based coating system.

2. **QUESTION:** ...Please find the technical data information for substrate repair (Duraseal PM) and corrosion barrier (Duraline epoxy).

**ANSWER:** The above products are not approved. The information provided and discovered concerning the Duraline PM and Duraline epoxy product is insufficient to approve as an equal for this project. Areas of concern include: design life of product, applicable references and warranty.

**Attachments:** none

Contacts for this proposal:

Joan M. Schouten CPIM CPPB; Procurement Officer; [JSchouten@wheaton.il.us](mailto:JSchouten@wheaton.il.us)